

TABLE 2

**Estimated Existing Quantity of Hauled Sewage and Septage
Municipalities of Grey County**

Property Class	No. of Properties with Septic/Holding Tanks	Size of Septic Tank (m ³)	Frequency of Septic Tank Pumpout (Years)	Average Septage/Hauled Sewage Generated per year (m ³ /yr)	Septage/Hauled Sewage Generated (m ³ /day)	Septage/Hauled Sewage to Be Disposed of Assuming Seasonal (Six Months) Haulage (m ³ /day)
Residential	10,967	4	3	14,623	40.06	80.12
Multi-Residential	77	12	1	924	2.53	5.06
Commercial	963	8	3	2,568	7.04	14.07
Industrial	139	8	2	556	1.52	3.05
Farm	6,509	4	3	8,679	23.78	47.55
Recreational	3,497	4	5	2,798	7.66	15.33
Resid-Condos	18	4	3	24	0.07	0.13
Institutional	337	8	2	1,348	3.69	7.39
TOTAL	22,507	-	-	31,519	86	172

Assumptions:

- Quantity of septage per household is estimated assuming that a typical septage tank pumpage is approximately 4 m³/household and that each household will pump their septic tank every three (3) years.
- For seasonal dwellings the quantity of septage is estimated assuming tank pumpage of 4 m³/household and each household will pump their septic tank every six (6) years.
- Industrial septic tank 8 m³ and emptied every 2 years
- Commercial Septic Tank 8 m³ and emptied every 3 years
- Institutional Septic Tank 8 m³ (and emptied every 2 years
- Property Class - Residential Condo - Individual Unit
- Property Class - Multi-Residential - Average of 8-9 Units - septic tank 12 m³, emptied every year
- 1 m³ = 220 Imperial Gallons