

**TABLE 6**

**Existing and 20-Year Design Hydraulic and Organic Loadings  
Porta Potty Wastewater  
(Assuming Six Month Treatment Period)**

<b>Port-a-Potty Parameters</b>	<b>Existing 2004</b>	<b>20-Year Design 2024</b>
Quantity of Porta Potty Wastewater (m <sup>3</sup> /day)	1.9	2.6
BOD <sub>5</sub> Loading (kg/day)	13	18
TKN Loading (kg/day)	1.3	1.8